ADDENDUM NO. 1

TO THE

DRAWINGS AND SPECIFICATIONS

FOR THE

Dunn Street Sidewalk Project

Issued From: The City of Bloomington

Engineering Department

Post Office Box 100

401 North Morton Street, Suite #130

Bloomington, Indiana 47402

Issue Date: June 15th, 2022 **Letting Date:** June 17th, 2022

This Addendum No.1 to the drawings and specifications shall supplement, amend and become a part of the Bid documents, plans, and specifications for the Dunn Street Sidewalk Project. All bids and construction contracts shall be based on these modifications to the original contract documents. Bidders shall acknowledge receipt of this Addendum on the Bid Form. Failure to do so may subject the Bidder to disgualification.

Item No. 1: Pre-bid Conference

A Pre-Bid Conference will not be held for this project. Below is a summary of questions asked during the bidding process.

Item No. 2: Ouestions and Answers

- (Q) Is grinding the stump an acceptable means of removal instead of excavating?
 - (A) Yes, grinding the stump to one (1) foot below finished grade is acceptable.
- (Q) Can #11 aggregate be used instead of #53 compacted aggregate?
 - (A) No. Refer to special provisions 'Utility Information' section regarding CenterPoint Energy's requirements for working around, and over the 2" and 10" gas mains. Considering Centerpoint's requirements the City will work with the contractor to find the best methods to achieve the desired compaction of the aggregate.

CERTIFIED BY: PATRICK DIERKES PROJECT ENGINEER CITY OF BLOOMINGTON, IN

Acknowledge receipt of the addendum by representing it on the Bid Form in Section B and submitting a signed copy with your bid proposal.

RECEIVED BY:	CONTRACTOR (FIRM AND ADDRESS)		
SIGNATURE:		D ATE:	
PRINTED NAME	:		
TITLE:			