

ADDENDUM NO. 1
TO THE
DRAWINGS AND SPECIFICATIONS
FOR THE
Winslow Resurfacing Project (Walnut to Allendale)

Issued From: The City of Bloomington
Engineering Department
Post Office Box 100
401 North Morton Street, Suite #130
Bloomington, Indiana 47402

Issue Date: March 8th, 2023

Letting Date: March 13th, 2023

This Addendum No.1 to the drawings and specifications shall supplement, amend and become a part of the Bid documents, plans, and specifications for the Winslow Resurfacing Project (Walnut to Allendale). All bids and construction contracts shall be based on these modifications to the original contract documents. Bidders shall acknowledge receipt of this Addendum on the Bid Form. Failure to do so may subject the Bidder to disqualification.

Item No. 1 Question: Please explain how and where Item 8 - B Borrow and Item 9 - Compacted Aggregate No. 53 are to be used on the project.

Item 8 B Borrow is intended for use as backfill at the Winslow-Allendale intersection. After pavement and aggregate removal in the southwest and southeast corners of this intersection, Item 8 B Borrow shall be used as backfill and then covered with 4 inches of Item 22 Topsoil and then Item 21 Mulched Seeding, U.

Item 9 Compacted Aggregate No. 53 is intended for use under new sidewalk and curbs. Sidewalks shall be installed on 4 inches of Item 9 Compacted Aggregate No. 53, and new curb/curb and gutter shall be installed on 6 inches of Item 9 Compacted Aggregate No. 53 if the existing base is unsuitable. Item 9 Compacted Aggregate No. 53 may also be used when necessary to fill under pavement patches.

Item No. 2: Question: Winslow Road has a high traffic volume during the day. Can the contractor have the option to do the milling and paving operations at night to avoid traffic congestion?

Bidders shall assume that all operations must comply with the City's noise ordinance. Bloomington Municipal Code (BMC) 14.09.040 allows for construction operations after 6am and before 10pm. Bidders shall refer to BMC for a full noise ordinance description which includes exceptions for Sundays and holidays and for unusually loud operations such as pneumatic hammers. The selected Contractor may request approval from the Board of Public Works to perform milling and paving operations at night, but they should be aware that the Board is likely to consider residential frontage as one factor in their decision.

	<p>CERTIFIED BY: <u>Neil Kopper</u></p> <p>NEIL KOPPER SENIOR PROJECT ENGINEER CITY OF BLOOMINGTON, IN</p>
--	---

Acknowledge receipt of the addendum by representing it on the Bid Form in Section B and submitting a signed copy with your bid proposal.

RECEIVED BY: CONTRACTOR (FIRM AND ADDRESS)

SIGNATURE: _____

DATE: _____

PRINTED NAME: _____

TITLE: _____